

DC MILLIAMP CLAMP LOGGER KEW 2510

Measures DC4+20mA signals without breaking the loop "Advanced model with recording function!"







Bluetooth

OUT

AUTO POWER

OFF

DC_mA

MEM


HOLD


- Actual size
- Measures 4 to 20 mA instrumentation and processes signals without breaking the loop
- Memory function stores up to 192,000 data useful for long-time signal monitoring and fault finding
- Transfer data to PC via Bluetooth®

- Top class measurement with 0.2% accuracy
- Ø6mm clamp jaw easy to use in tight places
- LED light for illuminating the measurement spot
- Analog output terminal to allow the connection to a recorder or a digital multimeter

KEW 2510 Specification

00/400 4/4 /		
20/100mA(Auto-ranging)		
±0.2%rdg±5dgt(0.00 to 21.49mA)		
±1.0%rdg±5dgt(21.0 to 120.0mA)		
ϕ 6mm max.		
Recorder: DC1000mV against DC100mA		
Bluetooth®		
IEC 61010-1 Pollution degree 2 IEC 61010-2-032, IEC 61326-1(EMC)		
		IEC 60529 IP40, EN50581 (RoHS)
-10 to +50℃, relative humidity 85% or less (no condensation)		
When using AC adapter:		
0 to +40°C, relative humidity 85% or less (no condensation)		
-20 to +60°C, relative humidity 85% or less (no condensation)		
R6/LR6(AA) (1.5V) x4 (Alkaline LR6 is recommended.)		
External supply (AC adapter 8320)		
Approx. 50 hours continuous with alkaline batteries		
(with Backlight, LED light and Bluetooth feature OFF)		
111(L)x61(W)x46(D)mm : Display unit		
104(L)x34(W)x20(D)mm : Sensor		
700mm : Sensor cable		
Approx. 310g(including batteries)		
8320(AC adapter), KEW Windows for 2510(Software)		
9096(Carrying case), LR6(AA)x4, Instruction manual		
Software installation manual		
7256(Output cord)		











Accessories

Optional accessory





Selection Guide

	2500	2510
DC 20/100mA	✓	✓
Conductor size φ6mm max	✓	✓
Analog output	✓	✓
Memory		✓
Data transmission (Bluetooth®)		✓
Power: Battery	✓	✓
Power: External supply		✓



Please read the "Safety Warnings" in the instruction manual supplied with the instrument thoroughly and completely Safety Warnings: If the Institution and Supplied with the Institution the Inst to operate the instrument on a correct power supply and voltage rating marked on each instrument.

For inquiries or orders:



KYORITSU ELECTRICAL **INSTRUMENTS** WORKS, LTD.

2-5-20, Nakane, Meguro-ku, Tokyo, 152-0031 Japan Phone:+81-3-3723-0131 Fax:+81-3-3723-0152

www.kew-ltd.co.jp

