



- Designed to IEC 61010-1, IEC 61557
- Data Memory: 300 measured results
- ODownload Results to PC by Using 8212 Data Communication Adapter through Optical RS-232C Port.


KEW MULTIFUNCTION TESTER
KEW 6010B


KYORITSU ELECTRICAL INSTRUMENTS WORKS,LTD.


#### **Specifications**

opeomodions .				
Continuity Testing				
	Measuring Range		20/200Ω (Auto-Ranging)	
	Open Circuit Voltage		>6V	
	Short Circuit Current		>200mA	
	Accuracy		±(3%rdq+3dqt)	
Insulation Resistance Testing				
	Measuring Range		20/200MΩ(Auto-Ranging)	
	Test Voltage		500/1000V	
	Open Circuit Voltage		+20%-0%	
	Rated Current		>1mA	
	Accuracy		±(3%rdq+3dqt)	
Ī	LOOP Impedance Testing			
	mpedance Range		20Ω/2000Ω	
	Rated Voltage		230V +10%-15% [50Hz]	
	Normal Test Current		20Ω: 25A/10ms	
			2000Ω: 15mA/350ms max.	
	Accuracy		±(3%rdg+8dgt)	
RCD Testing				
	Test Current	×1/2, ×1	10, 30, 100, 300, 500mA (2000ms)	
	(Test Current Duration)	FAST	150mA(50ms)	
	(,	DC	10,30,100,300mA (2000ms), 500mA(200ms)	
		Auto Ramp	Goes up by 10% from 20% to 110% of I∆n. 300ms x 10	
	Rated Voltage		230V+10%-15% 50Hz	
	Accuracy	Test Current	×1/2:-8%-2%	
	,		×1, FAST: +2%+8%	
			DC: +10%	
			Auto Ramp: ±4%	
		Trip Time	±(1%rdg+3dgt)	
Uc Testing				
Measuring Range			100V	
	Rated Voltage		230V +10%-15% [50Hz]	
	Test Current Accuracy		5mA at I∆n=10mA	
			15mA at I∆n=30/100mA	
			150mA at I∆n=300/500mA	
			+5%+15%rdg	
			±8dqt	
General				
Safety Standard			IEC61010-1 CAT. III 300V Pollution degree 2	
	canal y change and		IEC61557-1, 2, 3, 4, 6, 10, IEC60529 (IP40)	
	Power Source Dimensions Weight		R6 or LR6 x8	
			175(L) x 115(W) x 86(D) mm	
			840g approx.	
	Accessories		7025 (Test Lead), KAMP10 (Test Lead with IEC Connector)	
			Pouch for Test leads, Shoulder Strap, Shoulder Pad, Instruction Manual	
	Optionals		7133 (Distribution board test leads)	
	.,		8212 (Data Communication Adaptor), KEW Report (Software)	
			== (= iiii = :iiiiiaiiiaaaaiiii taaptoi), tterr tiopoit (oottivaro)	

### **Instrument Layout**








# **Accessories**











### **Optional Accessories**

# **MODEL 7133**

### MODEL 8212 Data Communication Adapter with "KEW Report"







#### "KEW Report" Software for report

"KEW Report" transfers measurement data from the KEW 6010B to a PC.

Print or import the data into your report. KEW 6010B is connected to a PC via an opticallyisolated RS232C interface cable

(Model 8212 Data Communication Adapter)



Please read the "Safety Warnings" in the instruction manual supplied with the instrument thoroughly and Safety Warnings: completely for correct use. Failure to follow the safety rules can cause fire, trouble, electrical shock, etc. Therefore, make sure to operate the instrument on a correct power supply and voltage rating marked on each instrument.

### For inquires or orders :



# **KYORITSU ELECTRICAL INSTRUMENTS** WORKS, LTD.

No.5-20, Nakane 2-chome, Meguro-ku, Tokyo, 152-0031 Japan Phone:81-3-3723-0131 Fax:81-3-3723-0152 URL:http://www.kew-ltd.co.jp E-mail:info@kew-ltd.co.jp Factories: Uwajima & Ehime

